



Standard Specification for Drain, Waste, and Vent (DWV) Plastic Fittings Patterns¹

This standard is issued under the fixed designation D3311; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reappraisal. A superscript epsilon (ϵ) indicates an editorial change since the last revision or reappraisal.

1. Scope*

1.1 This specification provides standard fitting geometries and laying lengths for plastic fittings intended for use in drain, waste, and vent applications. (See Specifications [D2661](#) and [D2665](#).)

1.2 Fittings meeting the requirements of this standard specification are designed for use with outside diameter controlled pipe. The inside diameter can vary significantly as the wall thickness and outside diameter varies and therefore is not suitable for use as a fitting socket.

1.3 The values stated in inch-pound units are to be regarded as standard. The values given in parentheses are mathematical conversions to SI units that are provided for information only and are not considered standard.

1.4 *This international standard was developed in accordance with internationally recognized principles on standardization established in the Decision on Principles for the Development of International Standards, Guides and Recommendations issued by the World Trade Organization Technical Barriers to Trade (TBT) Committee.*

2. Referenced Documents

2.1 ASTM Standards:²

¹ This specification is under the jurisdiction of ASTM Committee F17 on Plastic Piping Systems and is the direct responsibility of Subcommittee F17.63 on DWV. Current edition approved Aug. 1, 2017. Published August 2017. Originally approved in 1974. Last previous edition approved in 2016 as D3311 – 11(2016). DOI: 10.1520/D3311-17.

² For referenced ASTM standards, visit the ASTM website, www.astm.org, or contact ASTM Customer Service at service@astm.org. For *Annual Book of ASTM Standards* volume information, refer to the standard's Document Summary page on the ASTM website.

[D2661 Specification for Acrylonitrile-Butadiene-Styrene \(ABS\) Schedule 40 Plastic Drain, Waste, and Vent Pipe and Fittings](#)

[D2665 Specification for Poly\(Vinyl Chloride\) \(PVC\) Plastic Drain, Waste, and Vent Pipe and Fittings](#)

[F1498 Specification for Taper Pipe Threads 60° for Thermoplastic Pipe and Fittings](#)

3. Requirements

3.1 Fittings shall conform to the geometries and laying lengths as shown in [Tables 1-45](#) and [Figs. 1-5](#). Tolerances shall be $\pm 1/16$ in. unless otherwise specified.

3.2 Spigot and hub dimensions shall conform to the requirements of the referencing standard.

3.3 The exact outside shape of a fitting is not determined by the outline drawings shown in this specification but rather by the socket dimensions, wall thickness requirements, waterway, laying lengths, and any other critical dimensions that may be specified.

3.4 The pitch of sockets for patterns with 90° angles (except vent fittings) shall be 1/4 in./ft or 1° 12 min.

3.5 On double reducing sanitary tees, the *G2* dimension on branches will be calculated on the larger size and centerlines shall remain the same for both branches.


3.6 All other dimensions, materials and property requirements shall be in conformance with the referencing standard.

4. Keywords

4.1 DWV; fittings; plastic; Schedule 40; thermoplastic

*A Summary of Changes section appears at the end of this standard


TABLE 1 Bends, in. (mm)



Nominal Pipe Size	1/4 Bend	Long Sweep 1/4 Bend	1/8 Bend	1/6 Bend	1/16 Bend
	G	G	G	G	G
1 1/4	1 9/16 (40)	2 1/4 (57)	1 (25)	7/8 (22)	7/16 (11)
1 1/2	1 3/4 (44)	2 3/4 (70)	1 1/8 (29)	1 (25)	1/2 (13)
2	2 5/16 (59)	3 1/4 (83)	1 1/2 (38)	1 9/16 (33)	1 1/16 (17)
3	3 1/16 (78)	4 1/16 (103)	1 3/4 (44)	1 11/16 (43)	1 3/16 (21)
4	3 7/8 (98)	4 15/16 (125)	2 3/16 (56)	2 1/16 (52)	1 (25)
6	5 (min) (127)	9 (229)	2 (min) (51)	3 3/8 (86)	1 1/2 (38)
8	6 (152)	...	2 1/16 (52)	...	1 1/2 (38)
10	9 1/4 (235) ^A	...	2 5/8 (67) ^A	...	2 3/16 (56) ^A
12	10 1 1/16 ^A	...	3 1/8 (79) ^A	...	2 3/8 (60) ^A


^A 10 in. and 12 in. fittings dimensions are minimum

TABLE 2 Bends with Inlets, in. (mm)



Nominal Pipe Size	1/4 Bend with Low Heel Inlet		Long-Sweep 1/4 Bend with Low Heel Inlet		Long-Sweep 1/4 Bend with High Heel Inlet		
	G	N	G	N	G	N	GG
3 by 3 by 1 1/2	3 1/16 (78)	4 3/16 (106)	4 1/16 (103)	4 3/4 (121)
3 by 3 by 2	3 1/16 (78)	4 7/16 (113)	4 1/16 (103)	4 15/16 (125)	4 1/16 (103)	5 5/8 (143)	2 1/4 (57)
4 by 4 by 2	3 7/8 (98)	5 7/16 (138)	4 15/16 (125)	6 (152)

TABLE 3 Sanitary Tees, 45° Wyes, Combination Wyes and 1/8 Bends, in. (mm)



Nominal Pipe Size	Sanitary Tee Single and Double ^A		45° Wye, Single and Double		Combination Wye and 1/8 Bend Single and Double	
	GN	GJ	GN	GJ	GN	GJ
1¼	¾ (19)	1 ⁹ / ₁₆ (40)	1 ¹ / ₁₆ (27)	2 ⁹ / ₁₆ (65)	7 ¹ / ₁₆ (11)	2 ¹⁵ / ₁₆ (75)
1½	1 (25)	1¾ (44)	1 ¹ / ₈ (29)	2 ⁷ / ₈ (73)	½ (13)	3 ³ / ₈ (86)
2	1 ³ / ₈ (35)	2 ⁵ / ₁₆ (59)	1 ³ / ₈ (35)	3 ³ / ₈ (92)	1 (25)	4 ¹ / ₂ (114)
3	1 ¹³ / ₁₆ (46)	3 ¹ / ₁₆ (78)	1 ⁵ / ₈ (41)	5 (127)	1 ¹ / ₈ (29)	6 ⁵ / ₁₆ (160)
4	2¼ (57)	3 ⁷ / ₈ (98)	1 ⁷ / ₈ (48) ^D	6 ³ / ₈ (162)	1 ¹³ / ₁₆ (46)	8 ⁵ / ₈ (219)
6	3½ (89)	5 (127)	1¾ (44)	8 ⁷ / ₁₆ (214)	<i>B</i>	<i>B</i>
8	4½ (114)	6 (152)	2 ³ / ₈ (60)	11 ³ / ₄ (298)	<i>B</i>	<i>B</i>
10	5½ (140) ^C	9 ¹ / ₁₆ (246) ^C	2 ⁷ / ₁₆ (62) ^C	13 (330) ^C	<i>B</i>	<i>B</i>
12	6 ⁹ / ₁₆ (167) ^C	11 (279) ^C	2 ⁷ / ₈ (73) ^C	15 ³ / ₈ (391) ^C	<i>B</i>	<i>B</i>


^A Non-reducing double sanitary tees are for vent use only.

^B Combination wye and 1/8 bend is assembled from two standard fittings.

^C 10 in. and 12 in. fittings dimensions are minimum.

^D This dimension is a minimum with no upper maximum limit.


TABLE 4 Reducing Sanitary Tees, 45° Wyes, Combination Wyes, and 1/8 Bends, in. (mm)



Nominal Pipe Size	Sanitary Tee, Reducing Single and Double ^A				45° Wye, Reducing Single and Double			Combination Wye and 1/8 Bend Reducing Single and Double		
	G1	G2	G3	G4	G1	G2	G3	G1	G2	G3
1½ by 1¼ by 1¼	1 ¹ / ₁₆ (17) ^B	1½ (38) ^B	1 ¹ / ₁₆ (43) ^B	1 ¹ / ₁₆ (43) ^B	—	—	—	—	—	—
1½ by 1¼ by 1½	1 (25)	1¾ (44)	1¾ (44)	1¾ (44)	—	—	—	—	—	—
1½ by 1½ by 1¼	1 ³ / ₁₆ (21)	1 ¹ / ₁₆ (43)	1 ¹ / ₁₆ (46)	1 ¹ / ₁₆ (46)	—	—	—	½ (13)	¾ (83)	3 ³ / ₁₆ (81)
2 by 1¼ by 1½	1 ³ / ₁₆ (30)	1 ⁵ / ₁₆ (49)	2 ³ / ₁₆ (56)	2 ³ / ₁₆ (56)	—	—	—	—	—	—
2 by 1½ by 1½	1 ³ / ₁₆ (30)	1 ⁵ / ₁₆ (49)	2 ³ / ₁₆ (56)	2 ³ / ₁₆ (56)	¾ (19) ^B	2 ¹ / ₁₆ (71) ^B	2 ¹ / ₁₆ (75) ^B	9 ¹ / ₁₆ (14)	3 ¹ / ₁₆ (94)	3 ⁵ / ₈ (92)
2 by 1½ by 2	1 ³ / ₁₆ (35)	2 ⁵ / ₁₆ (59)	2 ⁵ / ₁₆ (59)	2 ⁵ / ₁₆ (50)	1 (25) ^B	3 ¹ / ₂ (89) ^B	3 ³ / ₈ (86) ^B	1 (25)	4 ¹ / ₂ (114)	4 ¹ / ₂ (114)
2 by 2 by 1¼	1 ³ / ₁₆ (30)	1 ⁵ / ₁₆ (49)	2 ³ / ₁₆ (56)	2 ³ / ₁₆ (56)	—	—	—	—	—	—
2 by 2 by 1½	1 ³ / ₁₆ (30)	1 ⁵ / ₁₆ (49)	2 ³ / ₁₆ (56)	2 ³ / ₁₆ (56)	1 ¹ / ₁₆ (27)	3 ⁵ / ₁₆ (84)	3 ⁷ / ₁₆ (87)	9 ¹ / ₁₆ (14)	3 ¹ / ₁₆ (170)	3 ⁵ / ₈ (92)
3 by 3 by 1½	1 ⁵ / ₁₆ (24)	1¾ (44)	2 ⁹ / ₁₆ (65)	2 ⁹ / ₁₆ (65)	½ (13)	3¾ (95)	4 ⁵ / ₁₆ (110)	1 ⁸ / ₁₆ (3)	3 ⁷ / ₁₆ (87)	4 ¹ / ₄ (108)
3 by 3 by 2	1 ³ / ₁₆ (30)	2 ¹ / ₈ (54)	2 ⁷ / ₈ (73)	2 ⁷ / ₈ (73)	7 ⁸ / ₁₆ (22)	4 ¹ / ₈ (105)	4 ⁵ / ₈ (117)	7 ¹ / ₁₆ (11)	4 ³ / ₄ (121)	5 ⁹ / ₁₆ (135)
3 by 3 by 2 by 1½	1 ⁵ / ₁₆ (24) ^B	2 ¹ / ₁₆ (52) ^B	2 ⁷ / ₁₆ (62) ^B	2 ¹ / ₂ (64) ^B	—	—	—	—	—	—
4 by 4 by 1½	1 ¹ / ₁₆ (27) ^B	2 (51) ^B	3¼ (83) ^B	3¼ (83) ^B	0 (0) ^B	3 ⁵ / ₁₆ (84) ^B	3 ¹ / ₂ (100) ^B	—	—	—
4 by 4 by 2	1 ¹ / ₈ (29)	2 ¹ / ₁₆ (52)	3 ⁵ / ₁₆ (84)	3 ⁵ / ₁₆ (84)	¾ (10)	4 ¹ / ₁₆ (119)	5 ⁹ / ₁₆ (141)	5 ¹ / ₁₆ (8)	4¾ (121)	5 ⁷ / ₈ (149)
4 by 4 by 3	1¾ (44)	3 (76)	3 ⁹ / ₁₆ (90)	3 ⁹ / ₁₆ (90)	1 ¹ / ₁₆ (27) ^B	5 ⁹ / ₁₆ (141) ^B	6 (152) ^B	1 ¹ / ₁₆ (27)	6 ³ / ₈ (162)	6 ⁷ / ₈ (175)
6 by 6 by 3	—	—	—	—	¾ (5) ^B	6 ¹ / ₁₆ (176) ^B	7 ⁷ / ₁₆ (189) ^B	1 ¹ / ₁₆ (17) ^B	7 ¹ / ₁₆ (198) ^B	8 ¹ / ₁₆ (224) ^B
6 by 6 by 4	2 ³ / ₁₆ (56) ^B	3 ⁵ / ₈ (92) ^B	4 ⁵ / ₁₆ (110) ^B	4 ⁵ / ₁₆ (110) ^B	¾ (5) ^B	6 ¹ / ₁₆ (170) ^B	7 ⁷ / ₁₆ (189) ^B	9 ¹ / ₁₆ (14) ^B	7 ¹ / ₁₆ (198) ^B	8 ¹ / ₁₆ (227) ^B
8 by 8 by 4	2 ⁵ / ₈ (67)	4 ¹ / ₈ (105)	5¼ (133)	5¼ (133)	¾ (10)	7 ⁵ / ₈ (194)	8 ⁵ / ₈ (219)	c	c	c
8 by 8 by 6	3 ⁹ / ₁₆ (90)	4 ¹ / ₁₆ (122)	5½ (140)	5½ (140)	1 (25)	9½ (241)	9 ¹ / ₁₆ (249)	c	c	c
10 by 10 by 4	-1½ (-38) ^B	8 ¹ / ₁₆ (221) ^B	10 ³ / ₈ (264) ^B	c	c	c
10 by 10 by 6	0	10 ¹ / ₈ (257) ^B	11¼ (286) ^B	c	c	c
10 by 10 by 8	1¼ (32) ^B	11½ (202) ^B	12 ⁷ / ₁₆ (316) ^B	c	c	c
12 by 12 by 4	-2 ⁷ / ₁₆ (-62) ^B	9¾ (248) ^B	11 ¹ / ₁₆ (284) ^B	c	c	c
12 by 12 by 6	-¾ (-19) ^B	11 ³ / ₁₆ (284) ^B	11 ¹ / ₁₆ (297) ^B	c	c	c
12 by 12 by 8	½ (13) ^B	12 ⁹ / ₁₆ (319) ^B	13 ⁷ / ₈ (352) ^B	c	c	c
12 by 12 by 10	1 ¹ / ₈ (29) ^B	14 (356) ^B	14 ¹ / ₁₆ (379) ^B	c	c	c


^A Non-reducing double sanitary tees are for vent use only.
^B This dimension is a minimum with no upper maximum limit.
^C Combination Wye and 1/8 bend is assembled from two standard fittings.

TABLE 5 60° Wyes, Single, and Double, in. (mm)




Nominal Pipe Size	GN	GJ
1½	1 ¹ / ₈ (40)	2 ⁷ / ₈ (73)
2	1 ³ / ₈ (37)	3 ⁵ / ₈ (92)
3	1 ⁵ / ₈ (37)	5 (127)

TABLE 6 Fixture Tees, in. (mm)



Nominal Pipe Size	G1	G2	G3
1½	1 ⁹ / ₁₆ (40)	1 ³ / ₁₆ (30)	1¼ (32)
2 by 1½ by 1½	1 ⁷ / ₁₆ (37)	1 ³ / ₁₆ (30)	1¼ (32)
2 by 2 by 1½	1 ⁷ / ₁₆ (37)	1 ⁵ / ₁₆ (33)	1¼ (32)


TABLE 7 Cleanout Tees, in. (mm)



Nominal Pipe Size	G	I
1½	1⅜ (30)	⅝ (16)
2	1½ (38)	⅝ (16)
3	1⅞ (48)	¾ (19)
4	2½ (64)	⅞ (22)
6	3½ (89) ^A	1⅝ (33) ^A
8	4⅞ (102) ^A	1½ (38) ^A


^A 6 in. and 8 in. fittings dimensions are minimum.

TABLE 8 Reducing Cleanout Tees, in. (mm)




Nominal Pipe Size	GN, min	GJ, min	I, min
10 by 10 by 8	5⅞ (132)	5½ (140)	1¾ (44)
12 by 12 by 8	6 (152)	5½	1⅞ (43)

TABLE 9 60° Reducing Wyes, Single and Double, in. (mm)




Nominal Pipe Size	G1	G2	G3
2 by 2 by 1½	1⅞ (27)	3⅞ (87)	3⅞ (87)
3 by 3 by 1½	½ (13)	3¾ (95)	4⅞ (110)
3 by 3 by 2	⅞ (22)	4⅞ (105)	4⅞ (117)

TABLE 10 Molded Nipples, in. (mm)



Nominal Pipe Size	OD	ID	Length
1½	1.900	1.500	½-in. increments from close to 18 in. long
2	2.375	1.939	
3	3.500	2.900	


TABLE 11 Vent Tees and ¼ Bend Vents, in. (mm)



Nominal Pipe Size	Vent Tee	¼ Bend Vent
1¼	1 (25)	1 (25)
1½	1⅜ (30)	1⅜ (30)
2	1½ (38)	1½ (38)
3	1⅞ (48)	1⅞ (48)
4	2½ (64)	2½ (64)
6	3½ (89) ^A	3½ (89) ^A
8	4½ (114) ^A	4½ (89) ^A
10	5⅞ (148) ^A	5⅞ (148) ^A
12	6⅞ (175) ^A	6⅞ (175) ^A


^A 6 in., 8 in., 10 in., and 12 in. fitting dimensions are minimum.

TABLE 12 Reducing Vent Tees, Single, and Double, in. (mm)




Nominal Pipe Size	GN, min	GJ, min
2 by 1½ by 1½	1¾ (30)	1½ (38)
2 by 2 by 1½	1¾ (30)	1½ (38)
3 by 3 by 1½	1¾ (30)	1⅞ (48)
3 by 3 by 2	1½ (38)	1⅞ (48)
6 by 6 by 4	2½ (64)	3⅞ (87)
8 by 8 by 4	2½ (64)	4½ (114)
8 by 8 by 6	3⅞ (92)	4½ (114)
10 by 10 by 4	3⅞ (92)	5⅞ (149)
10 by 10 by 6	3⅞ (92)	5⅞ (149)
10 by 10 by 8	3½ (89)	5⅞ (149)
12 by 12 by 4	3½ (89)	6⅞ (176)
12 by 12 by 6	4½ (114)	6⅞ (176)
12 by 12 by 8	4⅞ (124)	6⅞ (176)
12 by 12 by 10	6½ (165)	7½ (190)

TABLE 13 Pipe Increases, in. (mm)




Nominal Pipe Size	N, min
1¼ by 1½	1⅜ (10)
1½ by 2	1⅞ (13)
1½ by 3	1⅞ (28)
2 by 3	⅞ (22)
2 by 4	1⅜ (35)
3 by 4	1⅞ (24)
3 by 6	1⅞ (49)
4 by 6	1⅞ (30)
4 by 8	1⅞ (41)
4 by 10	2⅞ (56)
6 by 8	¾ (19)
6 by 10	1⅞ (40)
6 by 12	2⅞ (60)
8 by 10	1⅞ (33)
8 by 12	1⅞ (46)
10 by 12	1¼ (32)

TABLE 14 Trap Adapters, in. (mm)




<i>Without Stop</i>			<i>With Stop</i>
Nominal Pipe Size		N, min	A, min
1¼		3/16 (5)	1.250 (32)
1½		3/16 (5)	1.500 (38)
2		3/16 (5)	2.000 (51)
1¼ by 1½		3/16 (5)	1.250 (32)

TABLE 15 Hubs, in. (mm)




Nominal Pipe Size	A	C	N	AJ	CJ	N
2	2.94 (74.7)	2 3/8 (60)	3/8 (10)
3	3.448 (87.58)	1 11/16 (43)	5/16 (8)	3.94 (100.1)	2 5/8 (67)	7/16 (11)
4	4.493 (114.12)	1 15/16 (49)	11/32 (9)	4.94 (125.5)	2 7/8 (73)	1/2 (13)
Reducing 4 by 3	4.493 (114.12)	1 15/16 (49)	5/16 (8)	4.94 (125.5)	2 7/8 (73)	7/16 (11)

TABLE 16 Spigots, in. (mm)



Nominal Pipe Size	L2, min	L1, min	L3, min	M		AN
				max	min	
2	3½ (89)	4⅝ (117)	⅜ (10)	2.75 (69.9)	2.63 (66.8)	2.00 (50.8)
3	3¾ (95)	5⅝ (143)	⅜ (10)	3.88 (98.6)	3.63 (92.2)	3.00 (76.2)
4	4 (102)	6⅞ (156)	⅜ (10)	4.88 (124.0)	4.63 (117.6)	4.00 (101.6)


TABLE 17 Reducing Spigots, in. (mm)



PLASTIC SPIGOT, Reducing
Adapts Cast Iron Hub
to Plastic Pipe


Nominal Pipe Size	L2 min	L1 min	L3 min	M		AJ
				max	min	
2 by 1½	3½ (89)	4¼ (108)	⅜ (10)	2.75 (69.9)	2.63 (66.8)	2.00 (50.8)
3 by 1½	3¾ (95)	4½ (114)	⅜ (10)	3.88 (98.6)	3.63 (92.2)	3.00 (76.2)
3 by 2	3¾ (95)	4⅝ (117)	⅜ (10)	3.88 (98.6)	3.63 (92.2)	3.00 (76.2)
4 by 2	4 (102)	4⅞ (124)	⅜ (10)	4.88 (124.0)	4.63 (117.6)	4.00 (101.6)
4 by 3	4 (102)	5½ (140)	⅜ (10)	4.88 (124.0)	4.63 (117.6)	4.00 (101.6)

TABLE 18 P Traps, in. (mm)




Nominal Pipe Size	min GJ	min GGJ	min GGN	min GN	min R
1/4	4 1/8 (105)	3 3/8 (86)	3 (76)	1 3/8 (35)	1 5/8 (41)
1/2	4 7/32 (107)	3 5/8 (92)	3 (76)	1 3/8 (35)	1 5/8 (41)
2	7 1/4 (184)	4 1/16 (103)	5 (127)	2 1/4 (57)	2 1/2 (64)
3	8 7/16 (214)	6 5/16 (160)	6 1/4 (159)	2 5/8 (67)	3 1/8 (79)
4	10 13/16 (275)	7 7/8 (200)	8 1/16 (205)	3 7/16 (87)	4 1/16 (103)
6	17 3/4 (451)	12 3/4 (324)	11 3/4 (298)	4 3/4 (121)	6 3/8 (162)

TABLE 19 Double Fixture Fitting, in. (mm)



Nominal Pipe Size	G1	G2	G3	G4
1 1/2	3/8 (10)	3 3/16 (90)	2 7/16 (62)	2 7/16 (62)
2	3/8 (10)	4 9/16 (116)	3 1/16 (78)	3 1/16 (78)
3	1/2 (13)	6 3/4 (171)	4 1/2 (114)	4 1/2 (114)
Reducing:				
2 by 1 1/2 by 1 1/2 by 1 1/2	3/8 (10)	3 3/16 (90)	2 7/16 (62)	2 7/16 (62)
2 by 1 1/2 by 2 by 2	3/8 (10)	4 9/16 (116)	3 1/16 (78)	3 1/16 (78)
2 by 1 1/2 by 2 by 1 1/2	3/8 (10)	4 9/16 (116)	3 1/16 (78)	3 1/16 (78)


TABLE 20 Double Fixture Fitting, in. (mm)



Interchanges with Double Fixture Fittings

Nominal Pipe Size	Double Fixture Fitting					
	G1	G2	G3	G4	R1	R2
1½	¾ (10)	3⅞ (79)	2 ¹¹ / ₁₆ (68)	2 ¹¹ / ₁₆ (68)	3⅝ (92)	3⅝ (92)
2	¾ (10)	4¼ (108)	3½ (89)	3½ (89)	4½ (114)	4½ (114)
3	½ (13)	6¼ (159)	4 ¹⁹ / ₁₆ (125)	4 ¹⁹ / ₁₆ (125)	6⅝ (168)	6⅝ (168)
Reducing						
2 by 1½ by 1½ by 1½	¾ (10)	3⅞ (79)	2 ⁷ / ₈ (73)	2 ⁷ / ₈ (73)	3⅝ (92)	3⅝ (92)
2 by 1½ by 1½ by 2	¾ (10)	4¼ (108)	2 ⁷ / ₈ (73)	3½ (69)	3⅝ (92)	4½ (114)
2 by 1½ by 2 by 2	¾ (10)	4¼ (108)	3½ (89)	3½ (89)	4½ (114)	4½ (114)
3 by 2 by 3 by 3	½ (13)	6¼ (159)	4 ¹⁹ / ₁₆ (125)	4 ¹⁹ / ₁₆ (125)	6⅝ (168)	6⅝ (168)


TABLE 21 Single and Double Long Turn Tee, in. (mm)



Interchanges with Combination Wye ¼ Bend

Nominal Pipe Size	Single and Double Long Turn Tee			
	G1	G2	N	R
1¼	¾ (10)	3 ⁷ / ₁₆ (87)	3 ¹ / ₁₆ (78)	4¾ (121)
1½	7 ¹ / ₁₆ (11)	3 ¹⁵ / ₁₆ (100)	3½ (89)	5⅞ (149)
2	1 ¹ / ₁₆ (17)	5⅞ (130)	4 ⁷ / ₁₆ (113)	7 (178)
3	1 ¹ / ₁₆ (27)	7 ⁹ / ₁₆ (192)	6½ (165)	10⅞ (257)
4	1½ (38)	10 (254)	8½ (216)	13¼ (337)
6	2½ (64)	15 ³ / ₈ (391)	12 ⁷ / ₈ (327)	19 (483)

TABLE 22 Single and Double Long Turn Tee Reducing, in. (mm)




Interchanges with Reducing Combination Wye 1/8 Bend

Single and Double Long Turn Tee Reducing


Nominal Pipe Size	G1	G3	N	G2	R
1½ by 1¼ by 1¼	¾ (10)	3⅝ (92)	3⅛ (78)	3⅞ (87)	4¾ (121)
1½ by 1½ by 1¼	¾ (10)	3⅝ (92)	3⅛ (78)	3⅞ (87)	4¾ (121)
2 by 1½ by 1½	7⁄16 (11)	4⅜ (107)	3½ (89)	3¹⁵⁄₁₆ (100)	5⅞ (200)
2 by 1½ by 2	1¹⁄₁₆ (17)	5⅞ (130)	4⁷⁄₁₆ (113)	5⅞ (130)	7 (178)
2 by 2 by 1¼	¾ (10)	3¹³⁄₁₆ (97)	3⅛ (78)	3⅞ (87)	4¾ (121)
2 by 2 by 1½	7⁄16 (11)	4⁹⁄₁₆ (102)	3½ (89)	3¹⁵⁄₁₆ (100)	5⅞ (149)
3 by 3 by 1½	7⁄16 (11)	4¾ (121)	3½ (89)	3¹⁵⁄₁₆ (100)	5⅞ (149)
3 by 3 by 2	1¹⁄₁₆ (17)	5¹¹⁄₁₆ (128)	4⁷⁄₁₆ (113)	5⅞ (130)	7 (178)
4 by 4 by 1½	¾ (10)	5⅞ (132)	3⁹⁄₁₆ (90)	3¹⁵⁄₁₆ (100)	5⅞ (149)
4 by 4 by 2	¾ (16)	6⅞ (156)	4½ (114)	5⅞ (130)	7 (178)
4 by 4 by 3	1¹⁄₁₆ (27)	8⅛ (205)	6½ (165)	7⁹⁄₁₆ (192)	10⅞ (257)
6 by 6 by 2	9⁄16 (14)	7⅞ (181)	4⁹⁄₁₆ (116)	5⅞ (130)	7 (178)
6 by 6 by 3	1⁵⁄₁₆ (24)	9⅛ (230)	6⅞ (168)	7⁹⁄₁₆ (192)	10⅞ (257)
6 by 6 by 4	1½ (38)	11 (279)	8½ (216)	10 (254)	13¼ (337)
6 by 6 by 5	2 (51)	13⁵⁄₁₆ (338)	10¾ (273)	12¾ (324)	16 (406)

TABLE 23 Three-Way Ell, in. (mm)



Nominal Pipe Size	G1	G2	G3
1½	1¾ (44)	1¾ (44)	1¾ (44)
2	2⁵⁄₁₆ (59)	2⁵⁄₁₆ (59)	2⁵⁄₁₆ (59)
3	3⅛ (78)	3⅛ (78)	3⅛ (78)
4	3⁷⁄₈ (98)	3⁷⁄₈ (98)	3⁷⁄₈ (98)
Reducing			
2 by 1½ by 1½ (short)	1⅝ (41)	1⅝ (41)	1⅝ (41)
3 by 2 by 3	3⅛ (78)	2⅞ (73)	3⅛ (78)
2 by 1½ by 1½ (long)	1¹⁵⁄₁₆ (49)	2¾ (56)	2¾ (56)


TABLE 24 Two Way Cleanout, in. (mm)



Nominal Pipe Size	G
3	4 ¹ / ₁₆ (103)
4	4 ¹⁵ / ₁₆ (125)
6 ^A	6 ¹ / ₈ (156) ^A


^A 6 in. fittings dimensions are minimum

TABLE 25 Sanitary Tees, with Side Inlet, in. (mm)



Nominal Pipe Size	G1	G2	G3	G4	G5
Left-Hand Side Inlet					
1 ¹ / ₂ by 1 ¹ / ₂ by 1 ¹ / ₂ by 1 ¹ / ₂	2 ³ / ₄ (70)	1 ³ / ₄ (44)	1 ³ / ₄ (44)	1 ³ / ₄ (44)	1 ³ / ₄ (44)
2 by 2 by 1 ¹ / ₂ by 1 ¹ / ₂	3 ¹ / ₁₆ (94)	2 ⁵ / ₁₆ (59)	2 ⁵ / ₁₆ (59)	2 ⁵ / ₁₆ (59)	2 ⁵ / ₁₆ (59)
3 by 3 by 2 by 1 ¹ / ₂	3 ⁵ / ₁₆ (84)	2 ¹ / ₈ (54)	2 ⁷ / ₈ (73)	2 ⁹ / ₁₆ (65)	2 ¹ / ₈ (54)
3 by 3 by 2 by 2	3 ⁵ / ₁₆ (84)	2 ¹ / ₈ (54)	2 ⁷ / ₈ (73)	2 ⁷ / ₈ (73)	2 ¹ / ₈ (54)
3 by 3 by 3 by 1 ¹ / ₂	4 ⁷ / ₈ (124)	3 ¹ / ₁₆ (78)	3 ¹ / ₁₆ (78)	2 ⁹ / ₁₆ (65)	3 ¹ / ₁₆ (94)
3 by 3 by 3 by 2	4 ⁷ / ₈ (124)	3 ¹ / ₁₆ (78)	3 ¹ / ₁₆ (78)	2 ⁷ / ₈ (73)	3 ¹ / ₁₆ (94)
4 by 4 by 4 by 2	6 ¹ / ₈ (156)	3 ⁷ / ₈ (98)	3 ⁷ / ₈ (98)	3 ⁹ / ₁₆ (84)	5 (127)
Right-Hand Side Inlet					
3 by 3 by 2 by 1 ¹ / ₂	3 ⁵ / ₁₆ (84)	2 ¹ / ₈ (54)	2 ⁷ / ₈ (73)	2 ⁹ / ₁₆ (65)	2 ¹ / ₈ (54)
3 by 3 by 2 by 2	3 ⁵ / ₁₆ (84)	2 ¹ / ₈ (54)	2 ⁷ / ₈ (73)	2 ⁷ / ₈ (73)	2 ¹ / ₈ (54)
3 by 3 by 3 by 1 ¹ / ₂	4 ⁷ / ₈ (124)	3 ¹ / ₁₆ (78)	3 ¹ / ₁₆ (78)	2 ⁹ / ₁₆ (65)	3 ¹ / ₁₆ (94)
3 by 3 by 3 by 2	4 ⁷ / ₈ (124)	3 ¹ / ₁₆ (78)	3 ¹ / ₁₆ (78)	2 ⁷ / ₈ (73)	3 ¹ / ₁₆ (94)
4 by 4 by 4 by 2	6 ¹ / ₈ (156)	3 ⁷ / ₈ (98)	3 ⁷ / ₈ (98)	3 ⁹ / ₁₆ (84)	5 (127)
Side Inlet Both Sides					
3 by 3 by 2 by 1 ¹ / ₂ by 1 ¹ / ₂	3 ⁵ / ₁₆ (84)	2 ¹ / ₈ (54)	2 ⁷ / ₈ (73)	2 ⁹ / ₁₆ (65)	2 ¹ / ₈ (54)
3 by 3 by 2 by 2 by 2	3 ⁵ / ₁₆ (84)	2 ¹ / ₈ (54)	2 ⁷ / ₈ (73)	2 ⁷ / ₈ (73)	2 ¹ / ₈ (54)
3 by 3 by 3 by 1 ¹ / ₂ by 1 ¹ / ₂	4 ⁷ / ₈ (124)	3 ¹ / ₁₆ (78)	3 ¹ / ₁₆ (78)	2 ⁹ / ₁₆ (65)	3 ¹ / ₁₆ (94)
3 by 3 by 3 by 2 by 2	4 ⁷ / ₈ (124)	3 ¹ / ₁₆ (78)	3 ¹ / ₁₆ (78)	2 ⁷ / ₈ (73)	3 ¹ / ₁₆ (94)
4 by 4 by 4 by 2 by 2	6 ¹ / ₈ (156)	3 ⁷ / ₈ (98)	3 ⁷ / ₈ (98)	3 ⁹ / ₁₆ (84)	5 (127)

TABLE 26 Sanitary Tee, Double with Side Inlets, in. (mm)




Nominal Pipe Size	G1	G2	G3	G4	G5
Single Side Inlet					
3 by 3 by 3 by 3 by 1½	47/8 (124)	31/16 (78)	31/16 (78)	29/16 (65)	311/16 (94)
3 by 3 by 3 by 3 by 2	47/8 (124)	31/16 (78)	31/16 (78)	27/8 (73)	311/16 (94)
4 by 4 by 4 by 4 by 2	61/8 (156)	37/8 (98)	37/8 (98)	35/16 (84)	37/8 (min) (98)
Inlet Both Sides					
3 by 3 by 3 by 3 by 1½ by 1½	47/8 (124)	31/16 (78)	31/16 (78)	29/16 (65)	311/16 (94)
3 by 3 by 3 by 3 by 2 by 2	47/8 (124)	31/16 (78)	31/16 (78)	27/8 (73)	311/16 (94)
4 by 4 by 4 by 4 by 2 by 2	61/8 (156)	37/8 (98)	37/8 (98)	35/16 (84)	5 (127)

TABLE 27 Sanitary Tees, with Slip Joint, in. (mm)



Nominal Pipe Size	Sanitary Tee			Sanitary Tee Through Wall		
	G1	G2	G3, min	G1	G2	G3, min
1¼	2¼ (57)	1½ (38)	23/16 (56)	2¼ (57)	1½ (38)	3 (76)
1½	2¾ (70)	1¾ (44)	27/16 (62)	2¾ (70)	1¾ (44)	3 (76)
1½ by 1¼ by 1½	2½ (64)	1¾ (44)	27/16 (62)	2½ (64)	1¾ (44)	3 (76)


TABLE 28 Upright Wye, in. (mm)



Nominal Pipe Size	G1 min	G2 min	G3 min
2 by 2 by 2	5½ (140)	59/16 (132)	3¾ (95)
3 by 3 by 3	7½ (191)	77/8 (187)	5¼ (133)
Reducing			
2 by 2 by 1½	4¼ (108)	41/8 (105)	31/16 (78)
3 by 3 by 2	59/16 (132)	59/16 (135)	49/16 (116)

TABLE 29 Single 45° Wye, with Auxiliary Inlet, in. (mm)


NOTE 1—RH.AI = Right Hand Auxiliary Inlet
 LH.AI = Left Hand Auxiliary Inlet
 DBL.AI = Double Auxiliary Inlets
 V = Vent



Nominal Pipe Size	G1	G2	G3	G4	G5
3 by 3 by 1½ V by 1½ RH.AI	4¼ (108)	½ (13)	4⁵⁄₁₆ (110)	3³⁄₁₆ (81)	1¾ (44)
3 by 3 by 1½ V by 1½ LH.AI	4¼ (108)	½ (13)	4⁵⁄₁₆ (110)	3³⁄₁₆ (81)	1¾ (44)
3 by 3 by 2 V by 2 RH.AI	5 (127)	7⁄₈ (22)	4⁹⁄₁₆ (117)	3¼ (83)	2⁵⁄₁₆ (59)
3 by 3 by 2 V by 2 LH.AI	5 (127)	7⁄₈ (22)	4⁹⁄₁₆ (117)	3¼ (83)	2⁵⁄₁₆ (59)

TABLE 30 Vertical Closet Bend, with Auxiliary Inlets, in. (mm)

NOTE 1—RH.AI = Right Hand Auxiliary Inlet
 LH.AI = Left Hand Auxiliary Inlet
 DBL.AI = Double Auxiliary Inlets
 V = Vent



Nominal Pipe Size	G1	G2	G3	G4	G5	G6	G7
3 by 3 by 4 by 2V by 2 RH.AI	7½ (191)	5⅝ (137)	6⅞ (156)	3⁵⁄₃₂ (80)	2¾ (70)	2⅞ (73)	2⅞ (73)
3 by 3 by 4 by 2V by 2 LH.AI	7½ (191)	5⅝ (137)	6⅞ (156)	3⁵⁄₃₂ (80)	2¾ (70)	2⅞ (73)	2⅞ (73)
3 by 3 by 4 by 2V by 2 by 2 DBL.AI	7½ (191)	5⅝ (137)	6⅞ (156)	3⁵⁄₃₂ (80)	2¾ (70)	2⅞ (73)	2⅞ (73)

以上内容仅为本文档的试下载部分，为可阅读页数的一半内容。如要下载或阅读全文，请访问：<https://d.book118.com/238032112042006032>