

SIEMENS

SIMATIC HMI

WinCC V6.2

What's New in WinCC V6

Printout of the Online Help

<u>What is new in WinCC V6.2?</u>	1
<u>Licensing WinCC V6.2</u>	2
<u>Hiding Messages</u>	3
<u>User-defined menus and toolbars in runtime</u>	4
<u>WinCC Online Trend Control</u>	5
<u>WinCC/Redundancy</u>	6
<u>WinCC/Central Archive Server</u>	7
<u>WinCC/Connectivity Pack</u>	8
<u>Enhancements in WinCC Runtime</u>	9
<u>Other Innovations</u>	10

Printout of the Online Help

Safety Guidelines

This manual contains notices you have to observe in order to ensure your personal safety, as well as to prevent damage to property. The notices referring to your personal safety are highlighted in the manual by a safety alert symbol, notices referring only to property damage have no safety alert symbol. These notices shown below are graded according to the degree of danger.



Danger

indicates that death or severe personal injury **will** result if proper precautions are not taken.



Warning

indicates that death or severe personal injury **may** result if proper precautions are not taken.



Caution

with a safety alert symbol, indicates that minor personal injury can result if proper precautions are not taken.

Caution

without a safety alert symbol, indicates that property damage can result if proper precautions are not taken.

Notice

indicates that an unintended result or situation can occur if the corresponding information is not taken into account.

If more than one degree of danger is present, the warning notice representing the highest degree of danger will be used. A notice warning of injury to persons with a safety alert symbol may also include a warning relating to property damage.

Qualified Personnel

The device/system may only be set up and used in conjunction with this documentation. Commissioning and operation of a device/system may only be performed by **qualified personnel**. Within the context of the safety notes in this documentation qualified persons are defined as persons who are authorized to commission, ground and label devices, systems and circuits in accordance with established safety practices and standards.

Prescribed Usage

Note the following:



Warning

This device may only be used for the applications described in the catalog or the technical description and only in connection with devices or components from other manufacturers which have been approved or recommended by Siemens. Correct, reliable operation of the product requires proper transport, storage, positioning and assembly as well as careful operation and maintenance.

Trademarks

All names identified by ® are registered trademarks of the Siemens AG. The remaining trademarks in this publication may be trademarks whose use by third parties for their own purposes could violate the rights of the owner.

Disclaimer of Liability

We have reviewed the contents of this publication to ensure consistency with the hardware and software described. Since variance cannot be precluded entirely, we cannot guarantee full consistency. However, the information in this publication is reviewed regularly and any necessary corrections are included in subsequent editions.

Table of contents

1	What is new in WinCC V6.2?.....	1-1
2	Licensing WinCC V6.2.....	2-1
3	Hiding Messages	3-1
4	User-defined menus and toolbars in runtime	4-1
5	WinCC Online Trend Control	5-1
6	WinCC/Redundancy	6-1
7	WinCC/Central Archive Server	7-1
8	WinCC/Connectivity Pack.....	8-1
9	Enhancements in WinCC Runtime	9-1
10	Other Innovations	10-1
	Index.....	Index - 1

What is new in WinCC V6.2?

Introduction

This chapter contains some abbreviated information about the major novelties in WinCC V6.2 as compared to WinCC V6.0 SP4.

Overview

Version 6.2 of the scalable process visualization system SIMATIC WinCC offers new features not only for standard visualization but also for optimizing production through Plant Intelligence.

Innovations to the existing WinCC options and new additional options expand the functionality of the entire system:

- Windows elements such as menus and toolbars can be integrated immediately in the user interface of the runtime application.
- The message system has a new function "Alarm Hiding". You can hide messages if the volumen is high; this feature is especially helpful for use in larger systems.
- At the same time, Microsoft's latest database system SQL Server 2005 has also been integrated. Optionally, a Central Archive Server can be set up for central process data archiving with max. 120,000 archive tags.
- You can also configure, if required, a Windows PC as Connectivity Station with access to current and historical WinCC data in the database.

以上内容仅为本文档的试下载部分，为可阅读页数的一半内容。如要下载或阅读全文，请访问：<https://d.book118.com/288027126077006114>